



**OFFICE OF THE DEPUTY FIRE OFFICER,
BHUBANESWAR CIRCLE, BHUBANESWAR.**

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017 read with
Fire Prevention and Fire Safety "Amendment" Rules, 2019)

File No-224/2019- BBS.CIR

Certificate No-71/BBS.CIR

Dated-13.12.2019

This Certificate is valid up to 12.12.2021

(Apply for renewal at least three months before expiry)

Certified that the G+3 Oncology Building of Apollo Hospitals Enterprises Ltd. Situated over Plot No-91/16, Mouza-Samantapuri, Unit-15, Bhubaneswar consisting of total 01 (one) building was inspected by officers of Odisha Fire Service on 01.11.2019 & 11.12.2019 in presence of authorized person of said building and it has been found to comply with the fire prevention and safety requirements in accordance with Odisha Fire Prevention and Fire Safety Rules, 2017 read with Fire Safety "Amendment" Rules, 2019 and its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:-

Ground floor	---Usage---	Therapy room, Procedure room, Treatment Room , Medical Physicist, Electrical room etc
1 st floor	---Usage---	OPD room, AHU, Electrical room, etc.
2 nd floor	---Usage---	CT Scan, Computer, Pet Equip, Store, waiting room, Staff room, Pantry, Lab, Chemo stn rooms, etc
3 rd floor	---Usage---	Doctor Rooms, Patient Rooms, Wards, OPD room, etc

CONDITIONS: -

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc. provided in the building or premises, should be maintained by the occupier (s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire Drills/rehearsals should be organized at least once in six months by involving local fire station.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all towers/blocks of building/premises.

13/12/2019
 (R.C Majhi)

Deputy Fire Officer,
 Bhubaneswar Circle, BBSR
 Deputy Fire Officer
 Bhubaneswar Circle, Bhubaneswar

Memo No. 2107 - BBSR-CIR,

Dated-13.12.2019

Copy to Sri. Amar Kumar Behera, GM-Finance & Accounts, Apollo Hospitals Enterprises Ltd., Mouza-Samantapuri, Unit-15, Bhubaneswar for information & necessary action.


13/12/2019

(R.C Majhi)

Deputy Fire Officer,
Bhubaneswar Fire Circle, BBSR
Bhubaneswar Circle, Bhubaneswar
Dated-13.12.2019

Memo No. _____ - BBSR-CIR,

Copy submitted to the Chief Fire Officer, FPW, Cuttack for favour of kind information please.

~ Sd ~

(R.C Majhi)

Deputy Fire Officer,
Bhubaneswar Circle, BBSR

Memo No. _____ - BBSR-CIR,

Dated-13.12.2019

Copy submitted to the Fire Officer, Central Range, Cuttack for favour of kind information please.

~ Sd ~

(R.C Majhi)

Deputy Fire Officer,
Bhubaneswar Circle, BBSR

Memo No. _____ - BBSR-CIR,

Dated-13.12.2019

Copy to the Planning Member, Bhubaneswar Municipal Corporation, Bhubaneswar for information please.

~ Sd ~

(R.C Majhi)

Deputy Fire Officer,
Bhubaneswar Circle, BBSR