Environmental Consultants & Analytical Services

Recognised by ISO/IEC 17025:2005 (NABL), MoEF & CC, NABET-QCI, FSSAI, ISO 9001 : 2015 & OHSAS 45001 : 2018

AMBIENT NOISE LEVEL MONITORING REPORT

Issued to: M/s. APOLLO HOSPITALS 251, Sainik School Road, unit-15, Bhubaneswar-751005, Odisha,India.		Issued Date	17.01.2020
		Our Ref No	TC50642000000891F
		Your Ref No Your Ref Date	AHB/WO/BHU/Hospital/11 17.06.2019

TEST RESULTS

Units: dB(A)

S.No	Name of The Locations	Results Day Time	
1	Near Chiller Plant	62.4	
2.	Near PMGS Plant	60.9	
3.	Near WTP Plant	57.0	
4.	Near D.G Area (1 meters away from D.G set)	66.3	
5.	Near STP Plant	53.8	

Noise Level Ambient Standards

Area Code	Category of Area	Limits in dB (A) Day Time
A	Industrial Area	< 75
В	Commercial Area	< 65
C	Residential Area	< 55
D	Silence Zone	< 50

Page 1 of 1

Notes:

1. Noise monitoring were done as per standard method prescribed by IS 9876: 1981 (Reaffirmed-2001).

Good	15	ligo *
Prepared by	Checked by	Authorized Signatory T. Laxmikanth Reddy Technical Manager

VL/QEHS/5. 10/TR